

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.

No. 6908

Date : 20/12/2018

It is certified that an inspection team headed by CMO Hardoi (U.P.)
(Name of Officers
with designation) from Medical & Health Deptt. Hardoi (Name of
Department/Office) inspected the MAHARISHI VIDYA MANDIR Sr. Sec.
SCHOOL, SHAHJAHANPUR ROAD, KURRIYA, HARDOI (U.P.) (Name & Address of
the School) on _____ and found that the MAHARISHI VIDYA MANDIR
Sr. Sec. SCHOOL, HARDOI (U.P.) (Name of school) has safe
drinking water facilities for the students and members of staff of the institution and is maintaining
the hygienic sanitation condition in the school building & the campus as per the norms
prescribed by the Central/State/U.T Govt.

The above valid for a period of 01 year.

Signature with Seal : 

Name : Dr. C. G. G. G. G. (2017)

Designation : मुख्य चिकित्सा अधिकारी
हरदोई

To

MAHARISHI VIDYA MANDIR
Sr. Sec. SCHOOL, SHAHJAHANPUR ROAD,
KURRIYA, HARDOI (U.P.)

(Name & Address of the Institution)

प्रेषक,

अधिशाली अभियंता,
निर्माण खण्ड,
उ०प्र० जल निगम,
हरदोई।

सेवा में,

महर्षि विद्या मन्दिर,
(सीनियर सैकेण्ड्री स्कूल),
शाहजहाँपुर रोड, कुरिया,
हरदोई (उ०प्र०)।
फोन- 05852-235106

पत्रांक :

6203 / वि-10 / 78

दिनांक : 19/12/2018

विषय :-

जल परीक्षण के संबंध में।

महोदय,

उपरोक्त विषयक आपके पत्र सं० शून्य दिनांक 13.12.2018 के तारतम्य में आपके विद्यालय प्रांगण में अधिष्ठापित ट्यूबवेल के 02 नग जल नमूने जल परीक्षण हेतु खण्ड कार्यालय को प्राप्त कराये गये थे। परीक्षण संबंधी आवश्यक कार्यवाही पूर्ण कर 02 नग जल परीक्षण आख्या आवश्यक कार्यवाही हेतु प्रेषित की जा रही है।

संलग्नक : 02 नग जल परीक्षण आख्या।

शुद्धीय
19/12/18
(ए०के० त्रिपाठी)
अधिशाली अभियन्ता



OFFICE OF THE EXECUTIVE ENGINEER, CONSTRUCTION DIVISION.

U.P. JAL NIGAM, HARDOI

Water Testing Laboratory

CHEMICAL EXAMINATION OF WATER

TEST REPORT

Source of Sample..... Tube well - (North Kanha) Location of Source.....
Date of Sampling..... 15/12/18..... Village/Hemlet..... Maha Rishi Vidya Mandir
Date of Analysis..... 15/12/18..... Code No..... KARRIYA - Sahyampur Road
Sample collected by Sri..... Block..... HARDOI -
Tehsil/District -Hardoi.

Serial
Compos - 2
North
Kanha

SL No	Parameter	Quantity (P.P.M.)	Requirement (Desirable Limit) Mg/L	Permissible Limit in the Absence of Alternate Source Mg/L	Result
1	Color	<u>Colourless</u>	-	-	
2	Odour	<u>Colourless</u>	-	-	
3	Taste	-	-	-	
4	Ph	<u>7.41</u>	6.5	8.5	
5	Total dissolved Solids	<u>276</u>	500	2000	
6	Chloride	<u>40</u>	250	1000	
7	Fluorine as 'Fluoride' F	<u>0.93</u>	1.0	1.5	
8	Iron as 'Fe'	<u>0.31</u>	0.3	1.0	
9	Nitrates	<u>10.40</u>	45	100	
10	Nitrite	<u>NIL</u>	-	-	
11	Hardness total as 'Caco3'	<u>390</u>	300	600	
	(a) Temporary as 'Caco3'	-	-	-	
	(b) Permanent as 'Caco3'	-	-	-	
12	Alkalinity as 'Caco3'	<u>375</u>	200	600	
	(a) Phenolphthalien	-			
	(b) Methil Orange	-			
13	Turbi Dity	<u>4.90</u>	5 NTU	10 NTU	

NOTE
These paramts
(water spec)
are under
as 16/1-10500
Grit
Imp

The Sample received from... Sri. Sachin. R. J.E.

Tested by

Counter Signed

Chemist/Lab Assistant

Assistnat Engineer(lab)

Enc: No / V-10/

date.

Assistant Engineer (Lab.)

Copy to following for information and necessary action.

U.P. Jal Nigam
HARDOI

1-
2-

Assistnat Engineer(lab)

79



OFFICE OF THE EXECUTIVE ENGINEER, CONSTRUCTION DIVISION.

U.P. JAL NIGAM, HARDOI

Water Testing Laboratory

CHEMICAL EXAMINATION OF WATER

TEST REPORT

School
Campus - 1

Source of Sample..... Tube well..... Location of Source..... Mehta Rishi
 Date of Sampling..... 15/12/18..... Village/Hemlet..... Vidya Mandir
 Date of Analysis..... 15.12.18..... Code No..... Shahjahan Road, KURRIYA
 Sample collected by Sri..... Block..... Hardoi
 Tehsil/District -Hardoi.

SL No	Parameter	Quantity (P.P.M.)	Requirement (Desirable Limit) Mg/L	Permissible Limit in the Abdence of Altemate Soruce Mg/L	Result
1	Color	<u>Colourless</u>	-	-	
2	Odour	<u>Odourless</u>	-	-	
3	Taste	-	-	-	
4	Ph	<u>7.67</u>	6.5	8.5	
5	Total dissolved Solids	<u>293</u>	500	2000	
6	Chloride	<u>95</u>	250	1000	
7	Fluorine as 'Fluoride' F	<u>1.49</u>	1.0	1.5	
8	Iron as 'Fe'	<u>0.64</u>	0.3	1.0	
9	Nitrates	<u>17.00</u>	45	100	
10	Nitrite	<u>NIL</u>	-	-	
11	Hardness total as 'Caco3'	<u>440</u>	300	600	<u>2406</u>
	(a) Temporary as 'Caco3'	-	-	-	<u>Thise value is</u>
	(b) Permanent as 'Caco3'	-	-	-	<u>So far as</u>
12	Alkalinity as 'Caco3'	<u>430</u>	200	600	<u>under 95</u>
	(a) Phenolphthalien	-	-	-	<u>115-10500</u>
	(b) Methil Orange	-	-	-	<u>limit</u>
13	Turbi Dity	<u>6.69</u>	5 NTU	10 NTU	<u>mp</u>

The Sample received from.. Smt. Sushma Kr. JB.....

Tested by

Counter Signed

Chemist/Lab Assistant

Assistant Engineer (lab)

Enc: No / V-10/ date.

U.P. Jal Nigam
HARDOI

Copy to following for information and necessary action.

- 1-
- 2-

Assistant Engineer (lab)